

Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA


ENERGY & ENVIRONMENT DIVISION

To be presented at the ASHRAE Winter Meeting,
Chicago, IL, January 23-27, 1993, and to be
published in the Proceedings

The Energy Saving Potential of Precooling Incoming Outdoor Air by Indirect Evaporative Cooling

P. Chen, H. Qin, Y.J. Huang, H. Wu, and C. Blumstein

September 1992



**ENERGY & ENVIRONMENT
DIVISION**

REFERENCE COPY |
Does Not |
Circulate |
Bldg. 50 Library. |
LBL-32517
Copy 1

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. Neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or The Regents of the University of California and shall not be used for advertising or product endorsement purposes.

Lawrence Berkeley Laboratory is an equal opportunity employer.

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

**THE ENERGY SAVING POTENTIAL OF PRECOOLING INCOMING
OUTDOOR AIR BY INDIRECT EVAPORATIVE COOLING**

Peilin Chen, Huimin Qin, Yu Joe Huang
Hofu Wu, and Carl Blumstein

Energy & Environment Division
Lawrence Berkeley Laboratory
Berkeley, California 94720

September 1992

THE ENERGY SAVING POTENTIAL OF PRECOOLING INCOMING OUTDOOR AIR BY INDIRECT EVAPORATIVE COOLING

Peilin Chen, Huimin Qin, Yu Joe Huang,
Hofu Wu, and Carl Blumstein

Lawrence Berkeley Laboratory
University of California, Berkeley

ABSTRACT

This paper investigates the energy saving potentials of using indirect evaporative coolers to precool incoming outdoor air as the first stage of a standard cooling system. For dry and moderately humid locations, either exhaust room air or outdoor air can be used as the secondary air to the indirect evaporative precooler with similar energy savings. Under these conditions, the use of outdoor air is recommended due to the simplicity in installing the duct system. For humid locations, the use of exhaust room air is recommended because the precooling capacity and energy savings will be greatly increased. For locations with short cooling seasons, the use of indirect evaporative coolers for precooling may not be worthwhile.

The paper also gives some simplified indices for easily predicting the precooling capacity, energy savings and water consumption of an indirect evaporative precooler. These indices can be used for cooling systems with continuous operation, but further work is needed to determine whether the same indices are also suitable for cooling systems with intermittent operations.

INTRODUCTION

The application of indirect evaporative cooling (IEC) in arid locations is well known [Watt 1986]. The main advantages are the reduction of energy consumption and less use of mechanical refrigeration, thereby reducing the release of chlorofluorocarbons (CFCs). There is also interest in how to use IECs in humid and moderately humid locations where dehumidification of supply outdoor air is usually necessary, a function that cannot be performed by a simple indirect evaporative cooler. Some new applications have appeared including precooling incoming outdoor air by IEC [Supple et al. 1985, Peterson and Hunn 1985], desiccant systems with indirect and direct evaporative

cooling [Burns et al. 1985, Manley et al. 1985, Matsuki et al. 1983], improving the COP of a mechanical refrigeration system by sending the leaving secondary air from an IEC to an air-cooled condenser, etc. Precooling outdoor air by IEC is comparatively easy to use as a first stage of an air handling system. The size of the second stage (for example, a conventional air handling installation) can then be reduced with the result that both the first cost and the energy consumption of the second stage are lower. Therefore, a detailed investigation of the effect of precooling by IEC seems to be warranted.

THE ADVANTAGES OF PRECOOLING SUPPLY OUTDOOR AIR BY IEC

For non-residential buildings or buildings in humid and moderately humid locations, indirect evaporative cooling with or without direct evaporative cooling (1-stage or 2-stage) usually is not sufficient to meet cooling loads, but it can serve as a booster for mechanical refrigeration. In this case the role of the IEC is to precool the incoming outdoor air (Figure 1). The first stage is an IEC and the second stage is a conventional air handling unit (an air cooling coil, an air washer etc.). The IEC cools the incoming outdoor air (primary air). The secondary air can be either outdoor air (Figure 1a) or exhaust room air (Figure 1b). When outdoor air is used, the dry bulb temperature of the primary air will be lowered depending on the effectiveness of the IEC, but its humidity ratio will not be changed. This results in the reduction of the sensible, but not latent, cooling load of the second stage in comparison with the system without precooling. When exhaust room air is used as the secondary air, its temperature after direct evaporation sometimes may be lower than the dew point temperature of the primary air. In such cases, there may be some dehumidification, i.e., condensation, of the primary air, and reductions in both the sensible and latent loads of the second stage. In a hybrid system, the IEC for precooling outdoor air reduces both peak demand and total energy consumption in the cooling season. According to our computer simulation, for example, if a tube-type IEC is installed to precool the outdoor air it will provide a cooling capacity of more than 10 kW and a reduction of electric demand of the mechanical refrigeration greater than 3 kW per m^3/s of primary air in the hottest summer days in Sacramento, California.

ESTIMATING THE ENERGY SAVINGS OF IEC PRECOOLING

To estimate the energy saving potentials of precooling by IEC, calculations are made for various U.S. and Chinese cities using the bin method and an analytical heat and mass transfer IEC model developed previously by the authors [Chen et al. 1991]. As

described in that paper, the the calculated effectiveness of different IEC designs using the authors' model varied from 40 to 80% depending on the primary air flow rate, and agreed well with manufacturers' data. The following locations and IEC precooling configurations have been investigated :

1. 16 California climate zones as designated by the California Energy Commission, 8 other American cities (Fort Worth, San Antonio, Lake Charles, Miami, Phoenix, Atlanta, New York, and Chicago), and two Chinese cities (Beijing and Shanghai) are selected for calculations. The climates in these cities range from very arid to very humid (see Table 1). Hourly weather data for these locations have been processed to derive the number of hours falling within each 5°C and 0.002 humidity ratio band. Calculations are then carried out using the authors' IEC model for the bin-distribution of outdoor air parameters. Only those bins with temperatures greater than or equal to 25 °C are taken into account.
2. Two kinds of IECs (tube-type and plate-type) are studied. Calculations are made for the total precooling capacity, the total energy saving in comparison with mechanical refrigeration, the total water consumption for the cooling season.
3. Either outdoor air or exhaust room air is used as the secondary air. The flowrate of secondary air, L_2 , is fixed at 0.378 m³/s (800 cfm) for a typical plate-type IEC or for one core of a typical tube-type IEC.
4. The primary air flowrate, L_1 , is not fixed. The ratio of L_1/L_2 is in the range of 0.625 - 2.5 (for the tube-type) or 0.8 - 6.0 (for the plate-type).
5. When exhaust room air is used as the secondary air, it is assumed to be always at a dry bulb temperature of 25°C and a relative humidity of 50%.

RESULTS

The purpose of our calculations was to determine the effect of precooling by IEC on energy and water consumption. Previous research by the authors have shown that IEC performance varied with the primary and secondary air flows and the wet-bulb temperature of the entering air (L_1 , L_2 , and t_{wb}) [Chen et al. 1991]. Since L_2 is fixed by the manufacturer, and t_{wb} is determined by the climate, the primary design determinant of IEC effectiveness becomes the ratio of the primary to the secondary air flow rates (L_1/L_2). Three results were obtained for various L_1/L_2 ratios during the cooling season:

1) Total precooling capacity Q , which is the sum of the precooling capacity of each bin considered. The average hourly cooling capacity per m^3/s of primary air can be calculated as follows:

$$q = \frac{Q}{\text{bin hours} \times L_1} \quad (1)$$

where q = average hourly precooling capacity per m^3/s of primary air, $\text{kWh}/\text{h}(\text{m}^3/\text{s})$

Q = total cooling capacity in cooling season, kWh

bin hours = total hours with outdoor air dry bulb temperature $t \geq 25^\circ \text{C}$, h

L_1 = primary air flowrate, m^3/s

2) Total water consumption W , which is the sum of the water consumption due to evaporation in the secondary air flow for each bin considered. The average hourly water consumption per m^3/s of primary air can be calculated by Equation 2:

$$w = \frac{W}{\text{bin hours} \times L_1} \quad (2)$$

where w = average hourly water consumption for every $1 \text{ m}^3/\text{s}$ of primary air, $\text{kg}/\text{h}(\text{m}^3/\text{s})$

W = total water consumption in cooling season, kg

3) Total energy saving ES , which is the sum of energy saving due to precooling outdoor air by IEC in comparison with a conventional water chiller used to provide the equivalent precooling capacity for each bin considered. Power for fans and pumps in the refrigeration installation are taken into account using the following regression equations based on Warren (1985), assuming a chilled water temperature of 7°C :

$$\text{COP} = 3.517 / (0.4719 + 0.2232 \cdot t_{\text{cond}}) \quad (3)$$

where t_{cond} = condenser water temperature, $^\circ\text{C}$.

If t_{cond} is taken to be $t_{\text{wbo}} + 5.0$, the equation then becomes:

$$\text{COP} = 3.517 / (0.4719 + 0.2232 \cdot (t_{\text{wbo}} + 5.0)) \quad (4)$$

The average hourly energy saving per m^3/s of primary air is:

$$es = \frac{ES}{\text{bin hours} \times L_1} \quad (5)$$

where es = average hourly energy saving per m^3/s of primary air, $\text{kWh}/\text{h}(\text{m}^3/\text{s})$

ES = total energy saving in cooling season, kWh

In calculating Equation 5, the additional energy consumption due to the increased air resistance on both the primary and secondary sides is included. The values for q , es , and w are listed in Tables 2 through 5. The designs considered include typical tube-type IECs with L_1/L_2 ratios of 2.5 or 1.25, and typical plate-type IECs with L_1/L_2 ratios of 4.74 or 2.37. Results for other L_1/L_2 values are not listed in the tables, but they are evident in the subsequent figures.

Tables 2 and 3 assume that outside air is used as the secondary air, while Tables 4 and 5 assume that exhaust room air is used. For the latter case the cooling process of the primary air may include dehumidification because the dry bulb temperature of the secondary air after evaporation may be lower than the dew point temperature of the primary air. Lastly, when the enthalpy of the outdoor air is below that of indoor air, we use outdoor air instead of exhaust room air in our calculations.

For the arid California cities, when outdoor air is used as the secondary air the relationship between the average hourly energy saving (es) and water consumption (w) is nearly linear (Figure 2). For the non-California cities the situation is different except for Phoenix, which is very dry. When the secondary air is the exhaust room air the distribution is quite divergent and the relation between es and w cannot be expressed by any kind of curve.

The curves in Figure 2 have limited utility because for any city other than those cities calculated neither the abscissa nor the ordinate can be known without calculation in detail in advance. If we can find indices that are appropriate for all cities, these indices would be useful in predicting energy and water consumption for precooling outdoor air by IEC. Our results suggest that such indices do exist.

SIMPLIFIED INDICES OF IEC PRECOOLING POTENTIAL

For the case of outdoor air used as secondary air let q , es , and w be divided by average wet bulb temperature depression of outdoor air of the bins considered, the new parameters q_o , es_o , and w_o are obtained:

$$q_o = \frac{q}{\Delta t_m} \quad (6)$$

$$es_o = \frac{es}{\Delta t_m} \quad (7)$$

$$w_o = \frac{w}{\Delta t_m} \quad (8)$$

where Δt_m = average wet bulb temperature depression of outdoor air of the bins considered, °C

q_o = precooling capacity index, kWh/h°C(m³/s)

es_o = energy saving index, kWh/h°C(m³/s)

w_o = water consumption index, kg/h°C(m³/s)

Here subscript "o" means outdoor air applied as secondary air.

As shown in Table 3, the resultant "precooling indices", i.e., q_o , es_o , and w_o , are essentially the same for all California cities for the same values of L_1/L_2 . Their average values are as follows:

Type	L_1/L_2	q_o	es_o	w_o	Type	L_1/L_2	q_o	es_o	w_o
Tube	2.50	0.47	0.105	1.00	Plate	5.92	0.41	0.08	0.69
	1.25	0.61	0.16	1.67		4.74	0.47	0.11	0.82
	0.625	0.74	0.20	2.88		2.37	0.66	0.17	1.35
				1.00		0.86	0.23	2.53	

Figures 3 and 4 show two sets of curves by plotting the indices q_o , es_o , and w_o against the flowrate ratios L_1/L_2 for the tube and the plate-type precoolers. These curves can be applied to all California cities. The indices for non-California cities have very similar values.

For the case when exhaust room air is used as secondary air the indices can be obtained by following equations:

$$q_r = \frac{q}{t_{dbm} - t_{wbr}} \quad (9)$$

$$es_r = \frac{es}{t_{dbm} - t_{wbr}} \quad (10)$$

$$w_r = \frac{w}{t_{dbm} - t_{wbr}} \quad (11)$$

where t_{dbm} = average dry bulb temperature of outdoor air of the bins considered, °C

t_{wbr} = room air wet bulb temperature assumed to be constant over cooling season, °C

q_r = precooling capacity index, kWh/h°C(m³/s)

es_r = energy saving index, kWh/h°C(m³/s)

w_r = water consumption index, kg/h°C(m³/s)

Here, the subscript "r" means exhaust room air applied as secondary air.

These "precooling indices", i.e., q_r , es_r , and w_r , are shown in Table 5. As in the case when outdoor air is used, the indices using room air as the secondary air are constant for different locations, except that the water use indices (w) are comparatively discrepant. The reason for this is that outdoor air is used as secondary air when the outdoor air enthalpy is less than that of room air and the fraction of outdoor air used varies from site to site. The average values of the indices for California cities are listed in the following table:

Type	L_1/L_2	q_r	es_r	w_r	Type	L_1/L_2	q_r	es_r	w_r
Tube	2.50	0.52	0.12	1.34	Plate	5.92	0.46	0.10	0.71
	1.25	0.68	0.18	2.31		4.74	0.53	0.12	0.84
	0.625	0.83	0.23	4.14		2.37	0.74	0.20	1.37
1.00						0.97	0.26	2.50	

Figures 5 and 6 show the curves of indices plotted against the flowrate ratios L_1/L_2 . From the numbers in Tables 3 and 5 it also can be seen that the indices for non-California cities are close to the average values for California cities in the table above.

CONCLUSIONS

1) For California cities, using either outdoor air or exhaust room air as the secondary air provides nearly equal precooling capacity q (Tables 2 and 4). Slightly larger energy savings will be obtained if the secondary air is exhaust room air. But sometimes, especially for tube-type IECs, water consumption will also be larger. So there will be a trade-off between energy consumption and water consumption. In California, outdoor

air is probably preferable as the secondary air for precooling ventilation air in non-residential buildings because installation of the duct system will cost less. In humid locations like Miami, San Antonio Lake Charles, Fort Worth, or Shanghai, using exhaust room air as the secondary air gives much greater precooling capacity and energy savings. Although water consumption will be much greater, exhaust room air should still be preferable to outdoor air because in such locations water consumption is usually relatively inexpensive.

2) The indices presented in this paper are useful because they are suitable for all of California and the only variable is the flowrate ratio L_1/L_2 , which is always given in advance for any kind of calculation. So, it is easy to use them to predict the total precooling capacity, energy savings and water consumption during cooling season. The method of prediction is as follows:

When Outdoor Air is Used as the Secondary Air:

$$Q_o = q_o \times \Sigma \text{hours} \times \Delta t_m \quad (12)$$

$$ES_o = es_o \times \Sigma \text{hours} \times \Delta t_m \quad (13)$$

$$W_o = w_o \times \Sigma \text{hours} \times \Delta t_m \quad (14)$$

where Q_o = total precooling capacity, kWh

ES_o = total energy saving, kWh

W_o = total water consumption, kg

q_o, es_o, w_o = indices

Σhours = bin hours with outdoor air temperature $\geq 25^\circ\text{C}$

Δt_m = average outdoor air wet bulb temperature depression for the bins considered, $^\circ\text{C}$

When Exhaust Room Air is Used as the Secondary Air:

$$Q_r = q_r \times \Sigma \text{hours} \times (t_{dbm} - t_{wbr}) \quad (15)$$

$$ES_r = es_r \times \Sigma \text{hours} \times (t_{dbm} - t_{wbr}) \quad (16)$$

$$W_r = w_r \times \Sigma \text{hours} \times (t_{dbm} - t_{wbr}) \quad (17)$$

where Q_r = total precooling capacity, kWh

ES_r = total energy saving, kWh

W_r = total water consumption, kg

q_r, es_r, w_r = indices

t_{dbm} = average outdoor air dry bulb temperature of the bins considered, °C

t_{wbr} = room air wet bulb temperature assumed to be constant over the cooling season, °C

All the indices can be obtained according to the L_1/L_2 value from Figures 3 through 6. Of course, Σ hours, Δt_m , and t_{dbm} depend on the site, but these are not difficult to calculate if the bin-distributions of outdoor air parameters are available.

3) Since the indices are constant for a particular flowrate ratio L_1/L_2 the more bin hours, the more the precooling effect can be obtained. So for cities with a short cooling season (such as Oakland, Arcata, Santa Maria etc.) it may be not worthwhile to apply IEC as a first stage to precool incoming outdoor air. For cities with a longer cooling season (such as El Centro, Fresno, Riverside, China Lake etc.) precooling gives a very good energy saving effect.

4) The reduction of peak electric demand by precooling is apparent. The following table show some typical numbers for a typical tube-type IEC with outdoor air used as the secondary air:

If the secondary air is exhaust room air, the peak demand reduction for cities with comparatively long cooling seasons lies in the range of 3.5-5.5 kW.

5) The indices presented are for cooling systems with continuous operation. Further work is needed to determine whether the indices are suitable for cooling systems with intermittent operation.

REFERENCES

- Burns, P.R., Mitchell, J.W., and Beckman, W.A., 1985, "Hybrid Desiccant Cooling Systems in Supermarket Applications", ASHRAE Transactions, Vol. 91, Part 1.
- Chen, P.L., Qin, H.M., Huang, Y.J., and Wu, H.F., 1991, "A Heat and Mass Transfer Model for Thermal and Hydraulic Calculations of Indirect Evaporative Cooler Performance", Lawrence Berkeley Laboratory Report 28201, ASHRAE Transactions

City	L ₁ /L ₂	Peak Demand Reduction, kW, per 1 m ³ /s of primary air
El Centro	2.5	3.0
	1.25	3.8
Oakland	2.5	1.2
	1.25	1.7
Pasadena	2.5	2.2
	1.25	3.0
Sacramento	2.5	3.2
	1.25	4.0
Sunnyvale	2.5	3.2
	1.25	4.2

1991, Vol. 97, Part 2.

Manley, D.L. , Bowlen, K.L. , and Cohen, B.M., 1985, "Evaluation of Gas-Fired Desiccant-Based Space Conditioning for Supermarkets", *ASHRAE Transactions*, Vol. 91, Part 1.

Matsuki K., Tatsuoka M., and Tonomura T., 1983, "A Prototype Solar Desiccant Air-Conditioner", *Proceedings of the 18th Intersociety Energy Conservation Engineering Conference*, Vol. 4.

Peterson, J.L., and Hunn, B.D., 1985, "The Use of Indirect Evaporative Cooling to Reduce Peak Electric Demand in New Office Buildings", *ASHRAE Transactions* Vol. 91, Part 1B, No.2.

Supple, R.G. , and Broughton, D.R., 1985, "Indirect Evaporative Cooling - Mechanical Cooling Design", *ASHRAE Transactions*, Vol. 91, Part 1B, No.1.

Turner, R.H., and Chen, F.C., 1987, "Research Requirements in the Evaporative Cooling Field", *ASHRAE Transactions*, Vol. 93, Part 1.

Warren, M. 1985. *Conventional Cooling Systems*.

Watt, J.R. 1986. *Evaporative Air Conditioning Handbook*, Second Edition. Chapman and Hall.

Table 1. Climatic Parameters for Climate Locations Covered in Analysis

Location	Cool. Deg. Days 65°F	Cool. Deg. Hrs/24 75°F	Lat. Enth. Hrs/24 *	Location	Cool. Deg. Days 65°F	Cool. Deg. Hrs/24 75°F	Lat Enth. Hrs/24 *
<i>California cities</i>				<i>Other U.S. cities</i>			
1 (Arcata)	1	0	0.0	Fort Worth	2453	1045	490.1
2 (Santa Rosa)	920	527	0.7	San Antonio	2811	1077	540.1
3 (Oakland)	80	10	0.0	Lake Charles	2631	849	816.9
4 (Sunnyvale)	198	50	1.4	Miami	4005	1194	1154.7
5 (Santa Maria)	88	51	0.0	Phoenix	3661	2145	96.8
6 (Long Beach)	89	194	9.7	Atlanta	1543	405	284.4
7 (San Diego)	657	55	12.6	New York	1005	256	118.2
8 (El Toro)	826	243	11.3	Chicago	969	272	120.7
9 (Pasadena)	1053	372	10.2	<i>Chinese cities</i>			
10 (Riverside)	1313	676	3.9	Beijing	1583	607	303.8
11 (Red Bluff)	1925	958	3.0	Shanghai	1880	663	738.3
12 (Sacramento)	1166	540	1.5				
13 (Fresno)	916	916	2.0				
14 (China Lake)	2773	1672	0.0				
15 (El Centro)	4239	2610	60.4				
16 (Mt. Shasta)	552	212	2.2				

* Latent enthalpy hours calculated at base temperature of 75°F and humidity ratio of 0.0116; units are in Btu·hour/pound air)

Table 2. Precooling capacities for different indirect evaporative designs with outside air as secondary air

City	Bin hrs	Precooling capacity by IEC type and L_1/L_2^* (kWh/h per m ³ /s air)				Energy savings by IEC type and L_1/L_2^* (kWh/h per m ³ /s air)				Water use by IEC type and L_1/L_2^* (kg/h per m ³ /s air)			
		tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74
California climate locations													
Arcata (1)	72	5.26	4.00	5.60	3.93	1.35	0.84	1.42	0.85	14.3	8.5	11.6	6.9
China Lake (2)	3515	9.06	6.98	9.79	6.97	2.34	1.62	2.52	1.65	24.9	14.9	20.2	12.2
El Centro (3)	5004	9.51	7.37	10.36	7.44	2.55	1.79	2.77	1.84	26.0	15.7	21.3	13.0
El Toro (4)	1433	5.47	4.20	5.89	4.16	1.44	0.91	1.53	0.93	14.9	8.9	12.1	7.2
Fresno (5)	3446	7.84	6.07	8.53	6.10	2.12	1.45	2.29	1.49	21.4	12.9	17.5	10.6
Long Beach (6)	1966	5.40	4.15	5.82	4.11	1.43	0.90	1.52	0.92	14.7	8.8	11.9	7.2
Mount Shasta (7)	1787	6.69	5.14	7.21	5.11	1.76	1.16	1.88	1.18	18.3	11.0	14.8	8.9
Oakland (8)	441	5.26	4.01	5.61	3.93	1.35	0.84	1.42	0.84	14.3	8.5	11.6	6.9
Pasadena (9)	2186	6.29	4.84	6.78	4.79	1.66	1.08	1.77	1.10	17.1	10.3	13.9	8.4
Red Bluff (10)	2500	7.75	5.97	8.38	5.96	2.04	1.39	2.20	1.42	21.2	12.7	17.2	10.4
Riverside (11)	3230	7.45	5.76	8.08	5.75	1.98	1.34	2.14	1.37	20.4	12.2	16.6	10.1
Sacramento (12)	2086	6.96	5.38	7.55	5.37	1.88	1.26	2.02	1.29	19.0	11.4	15.5	9.4
San Diego (13)	3128	4.57	3.51	4.92	3.46	1.20	0.73	1.28	0.75	12.4	7.4	10.1	6.0
Santa Maria (14)	382	6.18	4.71	6.60	4.64	1.58	1.01	1.67	1.02	16.9	10.1	13.6	8.1
Santa Rosa (15)	1570	7.06	5.45	7.64	5.42	1.88	1.26	2.02	1.29	19.3	11.6	15.7	9.5
Sunnyvale (16)	1617	5.15	3.96	5.54	3.90	1.36	0.85	1.44	0.86	14.0	8.4	11.4	6.8
Other U.S. locations													
Fort Worth	3658	4.01	3.15	4.42	3.19	1.14	0.71	1.25	0.75	10.8	6.6	8.9	5.5
San Antonio	4737	4.40	3.45	4.84	3.50	1.25	0.80	1.36	0.84	11.9	7.2	9.8	6.0
Lake Charles LA	4737	3.18	2.50	3.52	2.54	0.92	0.53	1.00	0.58	8.5	5.2	7.1	4.3
Miami	7735	4.18	3.29	4.62	3.34	1.22	0.77	1.34	0.82	11.2	6.8	9.3	5.7
Phoenix	4316	7.78	6.06	8.49	6.11	2.11	1.46	2.29	1.51	21.3	12.9	17.4	10.6
Atlanta	2514	3.24	2.53	3.55	2.55	0.90	0.52	0.97	0.55	8.7	5.3	7.2	4.4
New York	1702	4.05	3.14	4.40	3.13	1.10	0.66	1.18	0.69	10.9	6.6	8.9	5.4
Chicago	1666	4.32	3.35	4.70	3.35	1.18	0.73	1.27	0.76	11.7	7.1	9.6	5.8
Chinese locations													
Beijing	2574	4.31	3.34	4.69	3.34	1.17	0.72	1.26	0.75	11.7	7.0	9.5	5.8
Shanghai	3191	3.16	2.48	3.44	2.49	0.91	0.53	0.98	0.56	8.4	5.2	6.9	4.2

* L_1/L_2 is the ratio of the primary and secondary air flow rates.

Table 3. Precooling indices for different indirect evaporative designs with outside air as secondary air

City	Avg. dry bulb temp. depres.	Precooling index by IEC type and L ₁ /L ₂ *				Energy savings index by IEC type and L ₁ /L ₂ *				Water use index by IEC type and L ₁ /L ₂ *			
		(kWh/h°C per m ³ /s air)		(kWh/h°C per m ³ /s air)		(kWh/h°C per m ³ /s air)		(kg/h°C per m ³ /s air)					
		tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74
California climate locations													
Arcata (1)	8.59	0.61	0.47	0.65	0.46	0.16	0.10	0.17	0.10	1.67	0.99	1.35	0.80
China Lake (2)	15.21	0.60	0.46	0.64	0.46	0.15	0.11	0.17	0.11	1.64	0.98	1.33	0.80
El Centro (3)	15.64	0.61	0.47	0.66	0.48	0.16	0.11	0.18	0.12	1.67	1.00	1.36	0.83
El Toro (4)	8.90	0.61	0.47	0.66	0.47	0.16	0.10	0.17	0.10	1.67	1.00	1.36	0.82
Fresno (5)	12.81	0.61	0.47	0.67	0.48	0.17	0.11	0.18	0.12	1.67	1.01	1.37	0.83
Long Beach (6)	8.76	0.62	0.47	0.66	0.47	0.16	0.10	0.17	0.11	1.68	1.00	1.36	0.82
Mount Shasta (7)	11.14	0.60	0.46	0.65	0.46	0.16	0.10	0.17	0.11	1.64	0.98	1.33	0.80
Oakland (8)	8.60	0.61	0.47	0.65	0.46	0.16	0.10	0.17	0.10	1.66	0.99	1.35	0.80
Pasadena (9)	10.30	0.61	0.47	0.66	0.47	0.16	0.11	0.17	0.11	1.67	1.00	1.35	0.81
Red Bluff (10)	12.74	0.61	0.47	0.66	0.47	0.16	0.11	0.17	0.11	1.66	1.00	1.35	0.82
Riverside (11)	12.24	0.61	0.47	0.66	0.47	0.16	0.11	0.18	0.11	1.66	1.00	1.36	0.82
Sacramento (12)	11.29	0.62	0.48	0.67	0.48	0.17	0.11	0.18	0.11	1.68	1.01	1.37	0.83
San Diego (13)	7.37	0.62	0.48	0.67	0.47	0.16	0.10	0.17	0.10	1.68	1.00	1.36	0.82
Santa Maria (14)	10.18	0.61	0.46	0.65	0.46	0.16	0.10	0.16	0.10	1.66	0.99	1.34	0.80
Santa Rosa (15)	11.52	0.61	0.47	0.66	0.47	0.16	0.11	0.18	0.11	1.67	1.00	1.36	0.82
Sunnyvale (16)	8.35	0.62	0.47	0.66	0.47	0.16	0.10	0.17	0.11	1.68	1.00	1.36	0.82
Other U.S. locations													
Fort Worth	6.38	0.63	0.49	0.69	0.50	0.18	0.11	0.20	0.12	1.69	1.03	1.40	0.86
San Antonio	7.07	0.62	0.49	0.69	0.50	0.18	0.11	0.19	0.12	1.68	1.02	1.39	0.85
Lake Charles LA	4.92	0.65	0.51	0.72	0.52	0.19	0.11	0.20	0.12	1.73	1.06	1.44	0.88
Miami	6.49	0.64	0.51	0.71	0.52	0.19	0.12	0.21	0.13	1.73	1.06	1.44	0.88
Phoenix	13.04	0.60	0.47	0.65	0.47	0.16	0.11	0.18	0.12	1.63	0.99	1.33	0.82
Atlanta	5.23	0.62	0.49	0.68	0.49	0.17	0.10	0.19	0.11	1.67	1.01	1.37	0.84
New York	6.53	0.62	0.48	0.67	0.48	0.17	0.10	0.18	0.11	1.68	1.01	1.37	0.83
Chicago	6.96	0.62	0.48	0.68	0.48	0.17	0.11	0.18	0.11	1.68	1.01	1.37	0.83
Chinese locations													
Beijing	6.96	0.62	0.48	0.67	0.48	0.17	0.10	0.18	0.11	1.68	1.01	1.37	0.83
Shanghai	4.91	0.64	0.51	0.70	0.51	0.19	0.11	0.20	0.11	1.72	1.05	1.41	0.87

*L₁/L₂ is the ratio of the primary and secondary air flow rates.

Table 4. Precooling capacities for different indirect evaporative designs with room air as secondary air

City	Bin hrs	Precooling capacity by IEC type and L ₁ /L ₂ * (kWh/h per m ³ /s air)				Energy savings by IEC type and L ₁ /L ₂ * (kWh/h per m ³ /s air)				Water use by IEC type and L ₁ /L ₂ * (kg/h per m ³ /s air)			
		tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74
California climate locations													
Arcata (1)	72	5.29	4.04	5.68	4.00	1.36	0.85	1.44	0.87	14.1	8.5	11.5	6.8
China Lake (2)	3515	9.11	7.03	9.97	7.11	2.36	1.64	2.57	1.69	23.9	14.4	18.6	11.5
El Centro (3)	5004	10.12	7.84	11.16	8.01	2.75	1.94	3.02	2.02	29.5	17.5	19.4	12.2
El Toro (4)	1433	6.06	4.65	6.57	4.64	1.61	1.05	1.73	1.07	25.3	14.2	12.5	7.6
Fresno (5)	3446	8.27	6.40	9.09	6.50	2.24	1.55	2.46	1.61	24.4	14.5	15.8	9.9
Long Beach (6)	1966	5.94	4.57	6.45	4.56	1.59	1.03	1.71	1.06	26.4	14.8	12.4	7.5
Mount Shasta (7)	1787	6.94	5.34	7.56	5.37	1.83	1.22	1.98	1.26	20.3	12.0	14.1	8.6
Oakland (8)	441	5.36	4.10	5.76	4.05	1.38	0.86	1.46	0.88	17.7	10.2	11.7	6.9
Pasadena (9)	2186	6.80	5.23	7.40	5.24	1.81	1.20	1.95	1.24	24.8	14.2	13.7	8.4
Red Bluff (10)	2500	8.02	6.19	8.78	6.25	2.13	1.45	2.32	1.50	24.9	14.6	16.0	9.9
Riverside (11)	3230	7.86	6.07	8.61	6.14	2.11	1.44	2.29	1.49	27.3	15.8	15.4	9.6
Sacramento (12)	2086	7.38	5.71	9.05	5.77	2.00	1.36	2.18	1.41	19.9	12.0	14.0	8.7
San Diego (13)	3128	5.26	4.03	5.69	4.01	1.41	0.89	1.50	0.91	29.3	16.0	11.2	6.7
Santa Maria (14)	382	6.19	4.73	6.67	4.70	1.58	1.02	1.69	1.04	18.9	11.1	13.5	8.1
Santa Rosa (15)	1570	7.39	5.70	8.08	5.75	1.98	1.30	2.15	1.38	21.2	12.6	14.6	9.0
Sunnyvale (16)	1617	5.47	4.20	5.92	4.18	1.45	0.92	1.55	0.95	21.6	12.2	11.5	6.9
Other U.S. locations													
Fort Worth	3658	7.20	5.25	7.40	5.11	2.14	1.37	2.18	1.36	25.0	14.1	12.5	7.7
San Antonio	4737	7.36	5.43	7.66	5.32	2.18	1.42	2.24	1.41	26.9	15.2	12.8	7.9
Lake Charles LA	4737	8.05	5.49	7.65	5.08	2.48	1.49	2.32	1.39	22.2	12.5	12.7	7.6
Miami	7735	8.04	5.69	8.02	5.57	2.46	1.54	2.42	1.53	19.1	11.2	13.0	8.0
Phoenix	4316	8.64	6.70	9.50	6.82	2.38	1.66	2.60	1.73	26.4	15.6	16.1	10.2
Atlanta	2514	6.31	4.50	6.30	4.27	1.85	1.13	1.82	1.08	22.2	12.4	11.3	6.8
New York	1702	5.91	4.37	6.13	4.28	1.67	1.04	1.71	1.04	20.8	11.8	11.4	6.9
Chicago	1666	6.16	4.60	6.46	4.53	1.75	1.11	1.81	1.13	20.3	11.7	11.7	7.1
Chinese locations													
Beijing	2574	7.50	5.37	7.52	5.07	2.19	1.37	2.16	1.30	29.4	16.3	13.1	7.8
Shanghai	3191	9.06	6.08	8.48	5.43	2.85	1.71	2.64	1.53	19.8	11.4	13.6	8.0

*L₁/L₂ is the ratio of the primary and secondary air flow rates.

Table 5. Precooling indices for different indirect evaporative designs with room air as secondary air

City	Avg. dry bulb temp. depres.	Precooling index by IEC type and L_1/L_2 * (kWh/h°C per m ³ /s air)				Energy savings index by IEC type and L_1/L_2 * (kWh/h°C per m ³ /s air)				Water use index by IEC type and L_1/L_2 * (kg/h°C per m ³ /s air)			
		tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74	tube 1.25	tube 2.50	plate 2.37	plate 4.74
California climate locations													
Arcata (1)	25.28	0.71	0.54	0.76	0.54	0.18	0.11	0.19	0.12	1.9	1.1	1.5	0.9
China Lake (2)	30.80	0.70	0.54	0.77	0.55	0.18	0.13	0.20	0.13	1.8	1.1	1.4	0.9
El Centro (3)	32.72	0.68	0.53	0.75	0.54	0.19	0.13	0.20	0.14	2.0	1.2	1.3	0.8
El Toro (4)	26.77	0.68	0.52	0.74	0.52	0.18	0.12	0.19	0.12	2.8	1.6	1.4	0.9
Fresno (5)	30.41	0.66	0.51	0.72	0.52	0.18	0.12	0.20	0.13	1.9	1.1	1.3	0.8
Long Beach (6)	26.75	0.67	0.51	0.72	0.51	0.18	0.12	0.19	0.12	3.0	1.6	1.4	0.8
Mount Shasta (7)	27.99	0.68	0.52	0.74	0.53	0.18	0.12	0.19	0.12	2.0	1.2	1.4	0.8
Oakland (8)	25.41	0.71	0.54	0.76	0.53	0.18	0.11	0.19	0.12	2.3	1.4	1.5	0.9
Pasadena (9)	27.78	0.68	0.52	0.74	0.53	0.18	0.12	0.20	0.12	2.5	1.4	1.4	0.8
Red Bluff (10)	29.56	0.68	0.53	0.75	0.53	0.18	0.12	0.20	0.13	2.1	1.2	1.4	0.8
Riverside (11)	29.56	0.67	0.52	0.73	0.52	0.18	0.12	0.20	0.13	2.3	1.4	1.3	0.8
Sacramento (12)	29.13	0.65	0.51	0.72	0.51	0.18	0.12	0.19	0.13	1.8	1.1	1.2	0.8
San Diego (13)	25.78	0.66	0.51	0.72	0.51	0.18	0.11	0.19	0.11	3.7	2.0	1.4	0.9
Santa Maria (14)	26.35	0.73	0.56	0.78	0.55	0.19	0.12	0.20	0.12	2.2	1.3	1.6	0.9
Santa Rosa (15)	28.91	0.67	0.51	0.73	0.52	0.18	0.12	0.19	0.13	1.9	1.1	1.3	0.8
Sunnyvale (16)	26.08	0.66	0.51	0.72	0.51	0.18	0.11	0.19	0.12	2.6	1.5	1.4	0.8
Other U.S. locations													
Fort Worth	28.25	0.69	0.50	0.71	0.49	0.20	0.13	0.21	0.13	2.4	1.4	1.2	0.7
San Antonio	28.67	0.67	0.50	0.70	0.49	0.20	0.13	0.21	0.13	2.5	1.4	1.2	0.7
Lake Charles LA	28.06	0.79	0.54	0.75	0.50	0.24	0.15	0.23	0.14	2.2	1.2	1.2	0.7
Miami	29.26	0.70	0.50	0.70	0.49	0.22	0.14	0.21	0.13	1.7	1.0	1.1	0.7
Phoenix	31.11	0.65	0.50	0.71	0.51	0.18	0.12	0.19	0.13	2.0	1.2	1.2	0.8
Atlanta	26.69	0.70	0.50	0.70	0.48	0.21	0.13	0.20	0.12	2.5	1.4	1.3	0.8
New York	26.51	0.68	0.50	0.70	0.49	0.19	0.12	0.20	0.12	2.4	1.4	1.3	0.8
Chicago	27.08	0.66	0.50	0.69	0.49	0.19	0.12	0.19	0.12	2.2	1.3	1.3	0.8
Chinese locations													
Beijing	27.66	0.76	0.54	0.76	0.51	0.22	0.14	0.22	0.13	3.0	1.6	1.3	0.8
Shanghai	28.42	0.85	0.57	0.80	0.51	0.27	0.16	0.25	0.14	1.9	1.1	1.3	0.8

* L_1/L_2 is the ratio of the primary and secondary air flow rates.

Figure 1. Cooling Systems using Indirect Evaporative Precooling





Figure 2. Relationship between Water Consumption (W) and Energy Savings (ES)



Legend

- | | |
|------------------------------------|-------------------------------------|
| ○ <u>Tube/2.5 arid locations</u> | + <u>Plate/4.74 arid locations</u> |
| ◦ <u>Tube/2.5 humid locations</u> | ⊠ <u>Plate/4.74 humid locations</u> |
| □ <u>Tube/1.25 arid locations</u> | × <u>Plate/2.37 arid locations</u> |
| ▣ <u>Tube/1.25 humid locations</u> | ⊞ <u>Plate/2.37 humid locations</u> |

Figure 3. Curves of Indices vs. Flowrate Ratio (L_1/L_2) for Tube Type Evaporative Cooler with Outdoor Air as Secondary Air




Figure 4. Curves of Indices vs. Flowrate Ratio (L_1/L_2) for Plate Type Evaporative Cooler with Outdoor Air as Secondary Air




Figure 5. Curves of Indices vs. Flowrate Ratio (L_1/L_2) for Tube Type Evaporative Cooler with Room Air as Secondary Air





Figure 6. Curves of Indices vs. Flowrate Ratio (L_1/L_2) for Plate Type Evaporative Cooler with Room Air as Secondary Air



LAWRENCE BERKELEY LABORATORY
UNIVERSITY OF CALIFORNIA
TECHNICAL INFORMATION DEPARTMENT
BERKELEY, CALIFORNIA 94720